

Agency Information

The certificate is only used for browsing on the web and proves that SETsafe | SETfuse has been certified.

If you need a FULL-VERSION certificate, please contact us: sales@SETfuse.com

该证书只用于在网页浏览，证明SETsafe | SETfuse已获得认证，如需要完整版本证书，请联系我们: sales@SETfuse.com

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

Product Produit	Surge Protective Device
Name and address of the Applicant Nom et adresse du demandeur	Xiamen SET Electronics Co., Ltd. No. 8067 West Xiang'an Road Torch High-Tech Industrial District, Xiang'an 361101, Xiamen China
Name and address of the manufacturer Nom et adresse du fabricant	Xiamen SET Electronics Co., Ltd. No. 8067 West Xiang'an Road Torch High-Tech Industrial District, Xiang'an 361101, Xiamen China
Name and address of the factory Nom et adresse de l'usine	Xiamen SET Electronics Co., Ltd. No. 8067 West Xiang'an Road Torch High-Tech Industrial District, Xiang'an 361101, Xiamen China
Rating and principal characteristics Valeurs nominales et caractéristiques principales	Test class II / Type 2, IP66 Uc = 320 V~, In = 10 kA, I _{max} = 25 kA, I _{sccr} = 1,5 kA Maximum overcurrent protection: C 32 A Circuit-breaker See further information on page 6 of report 3183404.50
Trademark (if any) Marque de fabrique (si elle existe)	SETfuse
Type of manufacturer's Testing Laboratories used Type de programme de laboratoire d'essais constructeur	
Model / Type Ref. Réf. de type	SD10C277XYZ, "XYZ" can be AHT, LHT, AH, LH, LH-D or LHT-D See further information on page 6 of report 3183404.50
Additional information (if necessary may also be reported on page 2) Les informations complémentaires (si nécessaire, peuvent être indiquées sur la 2ème page)	
A sample of product was tested and found to be in conformity with IEC Un échantillon de ce produit a été essayé et été considéré conforme à la CEI	61643-11(ed.1)
National differences / Comments Les différences nationales / Commentaires	EU Group Differences
As shown in the test report Ref. No. which forms part of this certificate Comme indiqué dans le rapport d'essais numéro de référence qui constitue partie de ce certificat	3183404.50

This CB Test Certificate is issued by the National Certification Body:

Ce Certificat d'essai OC est établi par l'Organisme National de Certification

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

